FIRE SAFETY CERTIFICATE

No. BJFS/01/23.

Dated. 21 09 23.

Certified that the Vidya Jyoti Academy (name of the building or premises) at Lower Samalbong, Fire Brigade Line, P.O. Bijanbari, Darjeeling(address) comprised of G+ 2 storied Building owned/occupied by Vidya Jyoti Academy(name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/UT FireService Rules, and verified by the officers concerned of Fire Service on 15/01/2021(date of inspection) in the presence of Arun Chhettri, Secretary, Vidya Jyoti Academy, Lower Samalbong, Fire Brigade Line, P.O. Bijanbari, Darjeeling (name and addresses of the Manager/ Secretary or his representative) and that the building/premises is fit for occupancy upto classes XII With effect from 21/01/2021 for a period of 3 (Three) year in accordance with rule and subject to compliance of specific conditions as appended:-

- 1. 2 pcs Fire Hydrant/Water Hydrant to be arranged.
- 2. Licensed holder electrician to be used for any electrical works.
- 3. Crowd to be controlled during any programme at the hall.

л	A	ID	A- I			C	Nia- at- u 8.6-	
4.	Awareness c	amp/Progr	amme to be	organised til	me to time	from the	Disaster ivia	nagement.

me to be organised time to time with the space (place) by

(date of issue) at Bijanbari Fire Station

Bijanbari Fire Station •Strike out whichever is not applicable. ne Bir Sirgh Konna
Designation: Sho officer.... Name & Address of Department! Office: Bijanborit/s west Bengal Fire & Emergency Service To

(Name & Address of the Institution)

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to

(reasons to be recorded).

(Name and designation of the authorized signatory)

• The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

VIDYA JYOTI ACADEMY BUANBARI

VIDYA JYOTI ACADEMY BIJANBARI



Government Of West Bengal Office Of The Divisional Fire Officer, Darjeeling West Bengal Fire & Emergency Services Station Feeder Road, P.O & P.S Siliguri, District: Darjeeling, Pin - 734005

Memo no.:IND/WB/FES/20182019/29382

Date: 21-01-2021

From:

Divisional Fire Officer, Darjeeling West Bengal Fire & Emergency Services

To: THE PRINCIPAL VIDYA JYOTI ACADEMY **BIJANBARI DARJEELING**

Sub: Renewal of Fire Safety Certificate of G+2 Storied Educational Building under group Educational at above noted address.

This is in reference to your application no. 0125191210500006 dated 12-01-2021 regarding the Renewal of Fire Safety Certificate of G+2 Storied Educational Building under group Educational at above noted address.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

Subject to fulfillment following conditions

- 1)Good housekeeping to be maintained both inside as well as outside the building
- 2)Floor Numbers as well as directional signs of escape routes to be prominently displayed
- 3)Fire Notice for evacuation and fire fighting to be prepared to display at all vulnerable places in the building
- 4)The occupants, employees and security staff to be made well-conversant about the installed fire safety and protection measures for their use in exigencies
- 5)Mock practice and fire evacuation drills to be organized for the regular periodical performance in accordance to the National Building Code - Part IV.
- 6)Electrical wiring of the afore said building should be checked and maintencence to be done by an licensed electrician.
- 7)Trained Firemen and Fire Officers in the form of prescribed crew to be maintained for round the clock safety of the

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number: 0125191210500006.

8)Mock practice and fire evacuation drills to be organized for the regular periodical performance in accordance to the National Building Code - Part IV.

9)All Exit & Entrance should be free from obstruction.

This certificate is valid for 3 year from the date issue u/r 18 of WBFS (Fire Prevention and Safety) Rules, 2018 (Amendment) and renewable after three year failing which this shall be revoked automatically.

Signature valid
Digitally signed by DEWAN
LEPCHA
Date: 2021.0 N.21 11:58:42 IST

Divisional Fire Officer, Darjeeling West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number: 0125191210500006.



To,

The Divisional Fire Officer,

West Bengal Fire & Emergency Services

Siliguri, West Bengal

(Through the Officer- In- Charge, West Bengal Fire & Emergency Services, Bijanbari)

Sub: Renewal of Fire Safety Certificate.

Respected Sir,

With due respect I would like to draw your kind attention that the fire Safety certificate issued by your esteemed office to our institution expires in the month of January, 2024.

Hence, you are requested for its renewal which helps to run our institution smoothly.

Thanking You,

Bijanbari, Darjeeling

Enclosure: Existing Fire Safety Certificate.

VIDYA JYOTI ACADEMY BIJANBARI

MANAGER VIDYA JYOTI ACADEMY **BIJANBARI**

Vidya iyoti Asademy Pocived by

Bijanhari, Carjering, Ives: Bung Asademy

A.S.E. AFF No. 2230176

School Code. 15747

West Beated Fire & Emergency Secretary



Ref. No. VJA/16/06/2025 - 25

Date: 15-10 4/2024

DECLARATION

We hereby declare that our institution Vidya Jyoti Academy, Bijanbari has applied for the renewal and extension of our fire certificate in accordance with the regulations stipulated by the relevant authorities.

However, despite our proactive efforts and timely submission of all required documents, we have encountered an unforeseen delay in obtaining the renewed fire certificate. This delay is primarily attributed to server issues on the fire server of the concerned authority.

We have diligently followed up with the appropriate channels to expedite the process, unfortunately, due to the technical difficulties beyond our control, the concerned authority has been unable to provide us with the renewed fire certificate by the expected date.

We are actively working to obtain the renewed fire certificate of our institution and will update it on our school website as soon as we get the certificate.

Thank you for your attention to this matter.

Principal

MANAGER
School Managing Canjuntite ACADEMY
Vidya Jyoti Acade BiyANBARI

Bijanbari, Darjeeling

Manager -

Vidya Jastin gate TIACADEMY

Bijanbari, Dance ANS ARI